



Ameya Agencies

ENGINEERING & FIRE SAFETY SOLUTION



Office : 215, Chhatrapati Nagar, Near M.S.E.B. Switch yard, Ring Road, Nagpur-440015 Ph.: 0712-2250779
Call : 08956623670, 09372072043, 09579285308 E-mail: contact@ameyafire.com, ameya_fire@yahoo.com Visit us at: www.ameyafire.com

License no-

MFS - LA/RF-254
MFS - LA/RD-538
MFS - LA/RP-41

Date-

26-04-2024

Inspection certificate of fire prevention and life safety measure (FORM -B)

To,
The secretary, Kasturba health society
Sevagram , Dist - Wardha

Certified that We have carried out inspection of the Fire Prevention and Life Safety Measures installed in the Hospital premises of the namely " Kasturba Hospital & Medical Collage (Hospital Building + Hostel building + MCH + New Auditorium + Palliative care) Kasturba health society. Sevagram , Dist - Wardha PIN No 442102

We further certify that the installations in the above mentioned Hospital are maintained in good repair and efficient conditions during the period July 2023 to - Dec - 2023 as required under the provisions of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006 (Mah III of 2007).

The details of the inspection of installations carried out by us are mentioned in the report appended herewith.

For, Ameya Agencies

ARVIND
PANDU
RANG
KHOBE
Digitally signed
by ARVIND
PANDURANG
KHOBE
Date: 2024.04.26
16:11:10 +05'30'

Mr. Arvind khobe

The details of the inspection of installations carried out by us

Sr. No.	Description	Qty	Work done	Remarks
1.	Fire hydrant system which included hydrant valve	66 nos.	Checked & tested by us	All system is in working condition
2.	Completed Fire hose reel drum	69 nos	Checked & tested by us	All system is in working condition
3.	Hose box with hose pipe & branch pipe	70 nos	Maintained	All system is in working condition
4.	Fire extinguisher all type	340 nos	Checked by us	All fire extinguisher is in working condition
5.	Pump -	03 no	Testing and trail	At the time of trail pump is working properly with the help of electric supply and with the help of generator.
	Fire jocky pump 180 LPM - 01 No			
	Fire main pump 1620 LPM - 01 no,			
	Fire Main diesel Generator driven fire pump of 1620 LPM - 01 Nos			
6.	Booster fire pump 450 LPM	13 Nos	Testing and trail	At the time of trail pump is working properly with the help of electric supply and with the help of generator.
7.	Fire Inlet Four way	02 nos	Maintained	All system is in working condition
8.	Fire Inlet Two way	13 Nos	Maintained	All system is in working condition

Office : 215, Chhatrapati Nagar, Near M.S.E.B. Switch yard, Ring Road, Nagpur-440015 Ph.: 0712-2250779

Call : 08956623670, 09372072043, 09579285308 E-mail: contact@ameyafire.com, ameya_fire@yahoo.com Visit us at: www.ameyafire.com

9.	Manual call point	90 nos	Checked & tested by us	All system is in working condition
10.	Electric hooter	47 nos	Checked & tested by us	All system is in working condition
11.	Smoke detector with base	46 nos	Checked & tested by us	All system is in working condition
12.	Control panel 12 Zone	12 nos	Checked & tested by us	All system is in working condition
13.	Control panel 8 Zone	01 Nos	Checked & tested by us	All system is in working condition
14.	Control panel 6 Zone	01 Nos	Checked & tested by us	All system is in working condition
15.	Control panel 2 Zone	13 Nos	Checked & tested by us	All system is in working condition

For, Ameya Agencies

ARVIND
PANDU
RANG
KHOBE

Digitally signed
by ARVIND
PANDURANG
KHOBE
Date: 2024.04.26
16:11:10 +05'30'